



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	8175-2405:0001
CATEGORY:	8175 - NONCOMBUSTIBLE MATERIALS
LISTEE:	Clicklad 1270 West 134 St, Gardena, CA, 90247 Contact: Weinstein, Shoham (213) 884-5748 Email: info@clicklad.com
DESIGN:	Model Clicklad Aluminum Siding. Product is 1.4 mm thick profile extruded 6063 aluminum. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	Noncombustible
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating, and QAI label.
APPROVAL:	Listed as noncombustible material for use as exterior siding in the Wildland Urban Interface areas. Refer to listee's Installation Instruction Manual for details. Model complies with the applicable requirements in ASTM E136-19.
NOTES:	

12/24/2024 GA



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/19/2026

Listing Expires: 06/30/2027

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division